

**ANDHRA PRADESH POWER GENERATION CORPORATION LTD**

To,  
The Principal,  
DAV High School,  
Dr.NTTPS.

Sir,

Sub: Dr.NTTPS-O&M-WTP-Chemical Division- Drinking Water Sample Test  
Results- Received from DAV High School -Regarding.

\*\*\*\*

It is herewith furnishing the Drinking Water sample results which were received  
from DAV High School, kondapalli on date:13.08.2024.

At DAV High School Dr.NTTPS Kondapalli	Parameters	pH	$\lambda$	P- alk	M- alk	TH	CaH	MgH	Cl <sup>-</sup>	TDS	Turbi dity	Res. Cl <sub>2</sub>
	Units		mc/cm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	NTU	ppm
	Results	7.58	364	NIL	126	106	74	32	66	243	2.0	NIL

Note: Safe for drinking purpose.

S.D. *[Signature]*  
EXECUTIVE CHEMIST  
WTP/O&M/Dr.NTTPS. 24/8/24

Copy Submitted to :

1) The Superintending Engineer/A&MM/Dr.NTTPS.