

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire Officer
Andhra Pradesh, NTR

To:
The District Educational Officer,
CHILAKALAPUDI, MACHILIPATNAM

File No: 31870/NTR/DFO/2026, Date:16/05/2026
Occupancy NOC RC Number: 6868/KRI/DFO/2019

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **DAV PUBLIC SCHOOL, represented by Dr.N.T.T.P.S., Dr.N.T.T.P.S., IBRAHIMPATNAM**, - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 6868/KRI/DFO/2019, Dt.22/03/2023
 4. Renewal NOC For Occupancy 6868/KRI/DFO/2019, Dt.22/03/2026
 5. Online Application for Renewal NOC of Dr.N.T.T.P.S., Dr.N.T.T.P.S., IBRAHIMPATNAM, - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 15-05-2026.

-- X --

The Management of DAV PUBLIC SCHOOL, represented by Dr.N.T.T.P.S., Dr.N.T.T.P.S., IBRAHIMPATNAM, has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.14620/- vide challan No. 11026055802026, Dated 22/04/2026 at STATE BANK OF INDIA, VTPS.

D.A.V.PUBLIC SCHOOL

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Dr.N.T.T.P.S. Dr.N.T.T.P.S., IBRAHIMPATNAM**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.



3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 22/03/2026 to 21/03/2028.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11026055802026	2026-04-22	14620

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

Nil

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Signature]
16.5.2026
District Disaster Response & Fire Officer,
NTR District

In case of emergency, please call 101 or 0866-2514851 or 9963728051

Copy to Management Dr.N.T.T.P.S., Dr.N.T.T.P.S., IBRAHIMPATNAM, KRISHNA DISTRICT
Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned